

SPA

Public Spa Pool Daily Record Sheet



Month / Year	Name of Pool:	Location – City
--------------	---------------	-----------------

Operator's Initials	DATE	Daily Pre-Opening Tests							Cyanuric Acid (1x / week)	Calcium Hardness (1x / week)	Free Cl / Br Readings (1 or 2 hrs)						Spa Drained (Monthly)	O.R.P.	Comments –
		Main Draw Visible	SPA Temp (<104°F.)	Free Chlorine	Combined Chlorine	pH	Total Alkalinity	Flow Rate GPM			Insert the Time the Test is Done (below)								
	1																		
	2																		
	3																		
	4																		
	5																		
	6																		
	7																		
	8																		
	9																		
	10																		
	11																		
	12																		
	13																		
	14																		
	15																		
	16																		
	17																		
	18																		
	19																		
	20																		
	21																		
	22																		
	23																		
	24																		
	25																		
	26																		
	27																		
	28																		
	29																		
	30																		
	31																		

Comments: _____

	Min.	Ideal	Max.
Free Chlorine	1.5 ppm	5.0 ppm	10 ppm
Combined Chlorine	0	0	0.5 ppm
Bromine	3.0 ppm	3.0-5.0 ppm	8.0 ppm
pH	7.2	7.3-7.5	7.6
Total Alkalinity	70 ppm	80-120 ppm	180 ppm
Calcium Hardness	175 ppm	250-300 ppm	-
Cyanuric Acid	0	5 - 30 ppm	50 ppm

SPA

Public Spa Pool Safety Checklist



Month / Year		License Number
Name of Facility		
Address		
Name of Operator		Phone

Monthly Safety Self-Inspection

<u>Item Checked</u>	<u>Maintenance Comments</u>
Spa & Enclosure	
? Fences – Openings < 4”, Good Repair	_____
? Doors & Gates – Self-Closes, Completely Latches, Good Condition	_____
? Window / Sliding Glass Door – Open < 4”	_____
? Deck Equipment – Good Condition, Fasteners and Fittings not corroded	_____
Stairs – Handrail tight	_____
? Depth Marking – Easily Readable	_____
? Deck – Clean, Disinfected, Good Repair, No Puddles, No Carpet/Matting/Wood	_____
? Spa Basin – In Good Repair	_____
? Skimmers / Gutters / Tile Line – Clean, Good Repair	_____
? Lighting – Maintained, Adequate	_____
? Safety Equipment – Provided, Good Repair	_____
First Aid Kit Stocked, Phone Working	_____
? Test Kit – Clean, Stocked w/ Fresh Reagents, Stored in Cool, Dry Location	_____
? Spa Temperature - <104°F. (Ideal 102°F. or less)	_____
? Water Changed – at least monthly, best changed when (“# of bathers” = Volume (gal.) / 3)	_____
Recirculation Equipment	
? Pumps / Filter / Chemical Feeders / Hair & Lint Strainer Maintained, Good Repair and Clean?	_____
? Gauges – Working, Accurate, Flow Meter Clean 2X Monthly, Check/Record Daily	_____
? Piping – All Pipes Marked, No Leaks, Exercise Valves and Heater Pop-off Monthly	_____